



## Improve HVAC System Efficiency

### Increase Cooling Efficiency

- ARI Guideline V provides a method for calculating the combined system efficiency of an Airxchange wheel with standard DX equipment. For a copy of the ARI Guideline V [Click here](#)
- Per Guideline V calculations, a typical Airxchange wheel preconditions outdoor air at efficiencies equivalent to 60 EER leading to 40% system efficiency improvement.
- Generally equivalent performance is available for air handling systems.
- Airxchange wheels provide up to 4 tons of cooling per 1000 cfm of outdoor air

### Increase Heating Efficiency

- The wheel has similar impact on the heating system reducing outdoor air heating costs by 70-80%
- Airxchange wheels provide up to 90 mbh of heating per 1000 cfm of outdoor air

### Example:

	DX System	DX / ERV System
<b>DX Cooling Capacity</b>	20 Tons	15 Tons
<b>ERV Cooling Capacity</b>	0 Tons	6 Tons
<b>Total Cooling Capacity</b>	20 Tons	21 Tons
<b>ERV Heating Capacity</b>	0	160 mbh
<b>Outdoor Air</b>	2000 CFM (25%)	2000 CFM (33%)
<b>EER</b>	10	13.3
<b>Peak Demand (kW)</b>	24	18
<b>Typical ERV Operating Savings</b>	-	\$2000 - \$5000

Above example assumes 95°DB / 78°WB outdoor air conditions for cooling calculations.

Heating calculations assume -16°DB / -17°WB outdoor air conditions.

Savings calculation assume utility rates of \$.08 kWh and \$1/therm.